

# Addendum

## Certificate No.: 14-019-01

**Applicant:** Changetec Technology GmbH  
Sölterreeke 5  
31832 Springe  
Deutschland

**Product type:** Grid monitoring interface between a generator and the public low-voltage grid

**Model:** BISI

**Rating:** 3x 380/400Vac, 50/60Hz

A representative test sample of above stated model and a XTM 4000-48 single phase inverter from Studer Innotec SA passed the test Loss of Mains Protection, according to Engineering Recommendation G59/3-2 Issue 3 Amendment 2 September 2015.

**Date of issue:** 2016-03-21



**Andreas Aufmuth**