

Addendum

Certificate No.: 14-018-00

Applicant: Changetec Technology GmbH
Sölterreeke 5
31832 Springe
Deutschland

Product type: Grid monitoring interface between a generator and the public low-voltage grid

Model: BISI

Rating: 3x 380/400Vac, 50/60Hz

A representative test sample of above stated model and a XTM 4000-48 single phase inverter from Studer Innotec SA passed the test Loss of Mains Protection, according to Engineering Recommendation G83/2 Issue 2 – August 2012.

Date of issue: 2016-03-21



Andreas Aufmuth